



अधिशाली अभियन्ता खण्ड कार्यालय,

उ० प्र० जल निगम (ग्रामीण), जालौन

Email Add.- eeoraidiv@gmail.com, Ph. (O) 05162-258025

पत्रांक 129

m-16 / 05

दिनांक- 17/01/2026

Morning Star Children's,
SR. SEC. Academy Orai School,
Karmer Road, Van Vibhag, Orai 285001,
Disst-Jalaun.

विषय:- जनपदीय जल परीक्षण प्रयोगशाला जालौन द्वारा पेयजल परीक्षण रिपोर्ट के सम्बन्ध में।

उपरोक्त विषयक Morning Star Children's, SR. SEC. Academy Orai School, Karmer Road, Van Vibhag, Orai 285001, Disst-Jalaun. के द्वारा पेयजल नमूने को एकत्र कर जनपदीय जल परीक्षण प्रयोगशाला में परीक्षण हेतु उपलब्ध कराया गया था, जिसके क्रम में जनपदीय जल परीक्षण प्रयोगशाला, जालौन द्वारा उक्त जल नमूने का परीक्षणोपरान्त NABL से Accredited प्रयोगशाला की जल परीक्षण रिपोर्ट संलग्न कर प्रेषित है।

संलग्नक:- उपरोक्तानुसार।

(ए०के० गुप्ता)
अधिशाली अभियन्ता

पृष्ठ संख्या एवं दिनांक यथोपरि:-

प्रतिलिपि:-निम्नलिखित को सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित है।

1-सम्बन्धित सहायक अभियन्ता/जूनियर इंजीनियर (प्रयोगशाला)।

अधिशाली अभियन्ता


Principal


Manager



Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural)
Orai, Jalaun



TC-13445

Analysis Water Test Report

ULR No.	TC-13445-2500000059F	Date - 14/01/2026
Customer Name	MORNING STAR CHILDREN'S ACADEMY	
Office Name and address	Karmar road, orai	
Ref. Letter No. & date	0 & 11/01/2026	

Basic details of sample

District	Jalaun	Block	Dakore
Gram Panchayat		Village/ Mohalla	Karmar road
Habitation		Location / Site name	Karmar road , orai
Latitude	25.989055	Longitude	79.472063
Water Source	Bore-well	Sample Number	1
Quantity of sample	1	Date of sample collection	13/01/2026
Sample receiving date	13/01/2026	Name of sample collector	Surendra singh
Name of Sample depositor	Ramnaresh	Date of Analysis Completion	14/01/2026
Date of Analysis Start	13/01/2026	Sampling method	IS Method

Technical Data of Analysis

S. No.	ANALYSED PARAMETER	Units	OBSERVED VALUES	SPECIFIED VALUES AS Per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH	-	7.40	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity	NTU	1.90	1.0	5.0	IS 3025 (Part 10) : 2023 (Nephelometer method)
3	Chloride (as Cl)	mg/L	37.30	250	1000	IS 3025 (Part 32) : 2019 (Silver Nitrate)
4	Total Hardness (as CaCO ₃)	mg/L	99.00	200	600	IS 3025 (Part 21) : 2019 (EDTA)
5	Calcium as Ca	mg/L	38.70	75	200	IS 3025 (Part 40) : 2023 (EDTA)
6	Alkalinity (as Na ₂ CO ₃)	mg/L	493.30	200	600	IS 3025 (Part 23) : 2023 (Indicator method)
7	Magnesium (as Mg)	mg/L	14.47	30	100	IS 3025 (Part 46) : 2023
8	Fluoride (as F)	mg/L	0.687	1.0	1.5	APHA 24th Edition -4500-F Method D (SPADNS Method)
9	TDS	mg/L	393.00	500	2000	IS 3025 (Part 16) : 2023 (Gravimetric method)
10	Colour	Hazen	2.40	5HU	15HU	IS 3025 (Part 04):2021
11	Taste	-	Agreeable	Qualitative	-	IS 3025 (Part 08):2023
12	Odour	-	Agreeable	Qualitative	-	IS 3025 (Part 05) :2023

NOTE:

- 1- This certificate refers only to the particular sample(s) submitted for testing.
- 2- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 3- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.


Prepared by
(Kapil Gupta)

Technical Manager


Reviewed by
(Priyanka devi)

Deputy Quality Manager


Authorized Signatory
(Manoj kumar)

QUALITY MANAGER

Technical Manager
District Water Analysis Laboratory
U.P.J.N., Jalaun

District Water analysis Laboratory
U.P.J.N. Jalaun


Principal


Manager

Morning Star Children's Academy, Orai

Principal

Manager

Analysis Report

District Level Water Analysis Laboratory, U.P. Jal Nigam (Rural) Orai, Jalaun
Analysis Water Test Report

Report Number	Bacteriological Test/59/2025/2026	Date - 14/01/2026
Costomer Name	Morning Start children's Academy	
Office Name and	Karmer Road Orai	
Ref. Letter No. & date	0 & 11/01/2026	

Basic details of sample

District	Jalaun	Block	Dakore
Gram Panchayat		Village/ Mohalla	Karmer Road
Habitation		Location / Site name	Karmer Road Orai
latitude	25.989055	longitude	79.472063
Water Source	Bore-well	Sample Number	1
Quantity of sample	1	Date of sample collection	13/01/2026
Sample receiving date	13/01/2026	Name of sample collector	Surendra Singh
Name of Sample	Ramnaresh	Date of Analysis Completion	14/01/2026
Date of Analysis Start	13/01/2026	Sampling method	IS Method

Technical Data of Analysis

S. No.	ANALYSED PARAMETER	OBSERVED VALUES	SPECIFIED VALUES AS Per IS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	pH	7.40	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Residual Chlorine (Mg/l)	0.00	0.2	1	IS 3025 (Part 26)
3	Total Coliform (CFU)	0.00	No relaxation	No relaxation	IS 10500:2012
4	E.Coli (CFU)	0.00	No relaxation	No relaxation	IS 10500:2012

NOTE:

- 1- This certificate refers only to the particular sample(s) submitted for testing.
- 2- This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- 3- The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
- 4- Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Contaminated

Not Contaminated


Prepared by
(Priyanka devi)
Microbiologist


Authorized Signatory
(Manoj kumar)
QUALITY MANAGER
District Water analysis Laboratory
U.P.J.N. Jalaun


Principal

Morning Star Children's Academy, Orai

Principal

Manager